

Type Approval
CERTIFICATE

N. C02 09C298001

Released by: **EuroTest Laboratori S.r.l.**
SINAL accredited laboratory UNI EN ISO/IEC 17025 N. 0192
SINAL is the EA member for accreditation of testing laboratories in Italy

Seeing test reports: PVC02 CdO 09C298001

Released by Eurotest Laboratori Srl Via dell'Industria, 18 – Brugine (PD) - Italy

We declare that the following product:

Photovoltaic Modules

Models list:

tested type: **AZM725/175**

extended by similarity (*)
see attached table

License holder:

AZIMUT SRL
Via dell'artigianato, 13 36050 Gambugliano (VI) - Italy

as results of test made complies the standard:

CEI EN 61215 (2006):

Crystalline silicon terrestrial photovoltaic (PV) modules. Design qualification and type approval.

Safety Class II Qualification Tests on PV Modules

To be used in plants at a total voltage up to

1000 Vdc (application Class A)

(*) The manufacturer declares that these products are constructed using the same materials, components and processes as the tested type AZM725/175. Further details on certified models are reported on the attachment.
Technical data, materials and components description are into the indicated test reports. Any changes of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

This certificate has a validity of 5 years.

Brugine, 24/06/2009

Laboratory head
Roberto Bolzonaro

Performed certification on tested model:

- complete certification
 retest performed according to IEC60088 “Retesting guideline” for similarity with model AZM725/175 (certificate n° C03 07C298001 & C04 07C2 98001 released by Eurotest Laboratori in date 30/06/2008).

with differences in:
 point k.: frameless module from a framed module

Tested type:

| Model name | cell number | cell size | cell technology | rated power |
|------------|-------------|-----------|-----------------|-------------|
| AZM725/175 | 72 | 125X125 | monocrystalline | 175 +/-3% |

Types extended for similarity without need of re-testing (according to IEC60088 “Retesting guideline”):

| Model name | cell number | cell size | cell technology | rated power |
|--------------|-------------|-----------|-----------------|-------------|
| AZM725/165ML | 72 | 125X125 | monocrystalline | 165 +/-3% |
| AZM725/170ML | 72 | 125X125 | monocrystalline | 170 +/-3% |
| AZM725/175ML | 72 | 125X125 | monocrystalline | 175 +/-3% |
| AZM725/180ML | 72 | 125X125 | monocrystalline | 180 +/-3% |
| AZM725/185ML | 72 | 125X125 | monocrystalline | 185 +/-3% |
| AZM365/80ML | 36 | 125X125 | monocrystalline | 80 +/-3% |
| AZM365/85ML | 36 | 125X125 | monocrystalline | 85 +/-3% |
| AZM365/90ML | 36 | 125X125 | monocrystalline | 90 +/-3% |
| AZM485/110ML | 48 | 125X125 | monocrystalline | 110 +/-3% |
| AZM485/115ML | 48 | 125X125 | monocrystalline | 115 +/-3% |
| AZM485/120ML | 48 | 125X125 | monocrystalline | 120 +/-3% |
| AZM325/75ML | 32 | 125X125 | monocrystalline | 75 +/-3% |
| AZM325/80ML | 32 | 125X125 | monocrystalline | 80 +/-3% |
| AZM405/95ML | 40 | 125X125 | monocrystalline | 95 +/-3% |
| AZM405/100ML | 40 | 125X125 | monocrystalline | 100 +/-3% |
| AZM445/100ML | 44 | 125X125 | monocrystalline | 100 +/-3% |
| AZM445/105ML | 44 | 125X125 | monocrystalline | 105 +/-3% |
| AZM445/110ML | 44 | 125X125 | monocrystalline | 110 +/-3% |
| AZM525/120ML | 52 | 125X125 | monocrystalline | 120 +/-3% |
| AZM525/125ML | 52 | 125X125 | monocrystalline | 125 +/-3% |
| AZM525/130ML | 52 | 125X125 | monocrystalline | 130 +/-3% |
| AZM565/130ML | 56 | 125X125 | monocrystalline | 130 +/-3% |
| AZM565/135ML | 56 | 125X125 | monocrystalline | 135 +/-3% |
| AZM565/140ML | 56 | 125X125 | monocrystalline | 140 +/-3% |
| AZM165/35ML | 16 | 125X125 | monocrystalline | 35 +/-3% |
| AZM165/40ML | 16 | 125X125 | monocrystalline | 40 +/-3% |
| AZM185/40ML | 18 | 125X125 | monocrystalline | 40 +/-3% |
| AZM185/45ML | 18 | 125X125 | monocrystalline | 45 +/-3% |
| AZM205/45ML | 20 | 125X125 | monocrystalline | 45 +/-3% |
| AZM205/50ML | 20 | 125X125 | monocrystalline | 50 +/-3% |
| AZM225/50ML | 22 | 125X125 | monocrystalline | 50 +/-3% |
| AZM225/55ML | 22 | 125X125 | monocrystalline | 55 +/-3% |
| AZM245/55ML | 24 | 125X125 | monocrystalline | 55 +/-3% |
| AZM245/60ML | 24 | 125X125 | monocrystalline | 60 +/-3% |

Additional notes

Laboratory head
Roberto Bolzonaro